

For use on LMI Series A and B chemical metering pumps.

**CAUTION**

When pumping chemicals make certain that all tubing is securely attached to the fittings. It is recommended that tubing or pipe lines be shielded to prevent possible injury in case of rupture or accidental damage. Always wear protective clothing when working on or near chemical metering pumps.

## NUMBER 95 LIQUID HANDLING ASSEMBLY

**A. INSTALLING INJECTION CHECK VALVE**

1. The injection check valve should always be installed as close as possible to the point of chemical injection, at the very end of the tubing run.

**CAUTION**

*Do not operate pump using 95 Liquid Handling Assembly without injection / anti-syphon valve properly installed.*

2. Purpose of injection / anti-syphon valve is to prevent backflow from *treated line* and to prevent syphoning or overpumping of chemical.

3. A 1/2" NPT female connection or tee will accept the injection / anti-syphon valve.

4. In order to insure correct seating of the ball inside the check valve, the injection / anti-syphon valve should be installed upwards.

**B. CONNECTING DISCHARGE TUBING**

Note: Cut tubing to length needed for discharge line making sure sufficient amount is left for suction line.

1. Route tubing from injection check valve to chemical metering pump making sure it does not touch hot surfaces, sharp surfaces, or is bent so sharply that it kinks.

2. Slide small end of coupling nut onto tubing.

3. Push tubing over tapered nozzle of pump head so that tubing flares out and reaches the shoulder. (If tubing is stiff from cold, dip end in hot water.)

4. Slide down the coupling nut until threads are engaged. Tighten by hand until tubing is held securely in place.

**CAUTION**

*Excessive force will crack or distort fittings. DO NOT USE PIPE WRENCH.*

5. Follow the same procedure for connecting tubing to injection valve.

**C. CONNECTING SUCTION TUBING**

1. Cut suction tubing to length necessary between suction valve of chemical metering pump and foot valve. Foot valve should just sit at the bottom of chemical container. Maximum recommended vertical suction lift is 5 ft. (1.5m)

2. Follow same procedure (see B) in connecting suction tubing to suction valve and foot valve.

**D. PRIMING**

1. Temporarily remove tubing from injection / anti-syphon valve and hold the end of tubing so it is above pump level.

2. Set pump at maximum speed and 100% stroke and start pump.

3. As soon as chemical is visible through translucent discharge tubing just past the discharge valve, stop the pump.

4. Pump is now primed.

5. Reconnect tubing to injection / anti-syphon valve.

Note:

(a) Pump is normally self-priming if suction lift is no more than 5 ft. (1.5m), valves in the pump are wet with water (Pump is shipped from factory with water in pump head and therefore valves are wet) and the above steps (D1 thru D3) are followed.

(b) If the pump does not self prime, remove discharge valve housing and ball and pour water or chemical slowly into discharge part until it is filled. Follow steps D2 through D5 thereafter.

**CAUTION**

*Do not remove injection / anti-syphon valve spring if pressure at injection point is less than 20 psi (1.4 kg/cm<sup>2</sup>) with electronic metering pumps, otherwise over-pumping will occur.*

**LIQUID METRONICS INCORPORATED**

3 JONES ROAD, WALTHAM, MASS. 02154 USA  
(617) 891-0690 TLX 92-3478

1036A  
replaces  
1036  
2C1278

**NOTE**  
 Maximum pump pressure rating is reduced by 25 psi (1.7 bar) with anti-syphon spring installed.

**PARTS LIST  
 NO. 95 LIQUID HANDLING  
 ASSEMBLY**

Ref. No.	Part No.	Description	Quantity
1	10394	Injector Fitting	1
2	10339*	Spring, Teflon PFA coated	1
3	10338*	Ball, Ceramic	4
4	10307*	Seal Ring, Fluorosilicone	4
5	10392	Valve Seat, Ivory, Polypropylene	2
6	10399	Coupling Nut, Ivory, Polypropylene	4
7	10342	Tubing, Polyethylene, 3/8" OD x 1/4" ID	16 ft.
8	10393	Valve Housing, Ivory, Polypropylene	2
9	10313M	Head, Ivory, Polypropylene	1
10	10302*	Liquifram, 0.9 SI Teflon Face	1
11	10340	Screw, 10-24 x 3/4 S.S.	4
12	10322	Weight, Ceramic	1
13	10978	Foot Valve Seat, black Polypropylene	1
14	10123	Strainer, white Polypropylene	1
15	10538	Injection/Anti-Syphon Valve Assy	1
16	10539	Discharge Valve Assembly	1
17	10540	Suction Valve Assembly	1
18	10541	Foot Valve Assembly	1
19	10542M	Head Assembly, L.E. 95	1

**\*PARTS INCLUDED IN  
 SPARE PARTS KIT NO.**

**SP - 95**

